

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

174

Dated: 29/01/2024

It is certified that an inspection team headed by SH. SUNIL KUMAR, SUB-DIVISIONAL ENGINEER
 (Name of Officers with designation) from PUBLIC HEALTH ENGINEERING DEPTT.
 (Name of Department/ Office) inspected the VIJAYA SR. SEC. SCHOOL, LOWA KHURD
 (Name & Address of the school) on 23/01/2024 (date of inspection) and found that the
VIJAYA SR. SEC. SCHOOL (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 6 months.

Signature with Seal: [Signature]
 Name: SUNIL KUMAR
 Designation: SUB-DIVISIONAL ENGINEER
 Name & Address of the Office / Department: PHE SUB DIVISION NO-2 Bahadurgarh

To

PRINCIPAL

VIJAYA SR. SEC. SCHOOL
VILLAGE LOWA KHURD DISTT JHAJJAR
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]
 Chairman

Vijaya Educational Society
 Bahadurgarh-124507 (Hr.)

[Signature]
 Principal
 Vijaya Sr. Sec. School
 Lowa Khurd, Bahadurgarh



WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT,
JHAJJAR
E-mail:-chemistjir@gmail.com



TC-9352
PHEDJJR 7.8 F-01

Test Report

Test Report No.:-CH-822/2024	ULR No.:-TC-93522300000811F
Issue To:- PHESD No.2 Bahadurgarh	Issue Date:-29.01.2024
Memo No.:-39	Sample Description:-Drinking Water
Sample Type:-Chemical Analysis	Sample Received on Date:- 23.01.2024
Sample Submitted by:- Sh. Anil	Date of Analysis Started:- 23.01.2024
Sample Location:- Vijaya Sr. Sec. School, Village Lowa Khurd	Date of Analysis Completed:- 23.01.2024
Sample Quantity:- 2 Litre	

RESULTS


S. No.	Parameter	Protocol Used	Results	IS:10500:2012(Second Revision)(RA -2018)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
	Total Dissolved Solids (TDS) at 180°C	APHA2540 C	153	500	2000	mg/L
2	Total Hardness as CaCO ₃	APHA2340 C	49.52	200	600	mg/L
3	Calcium (as Ca)	APHA3500-Ca B	12.22	75	200	mg/L
4	Magnesium (as Mg)	APHA3500-Mg B	4.63	30	100	mg/L
5	Chloride (as Cl)	APHA4500-Cl B	18.43	250	1000	mg/L
6	Total Alkalinity as CaCO ₃	APHA 2320 B	31.64	200	600	mg/L
7	Turbidity	APHA 2130 B	Less than 1	1	5	NTU
8	Colour	IS-3025(Part 4)	1	5	15	Hz
9	pH at 25°C	APHA 4500-H ⁺ B	7.35	6.5-8.5	No relaxation	-
10	Odour	IS-3025(Part 5)	Agreeable	Agreeable	Agreeable	-
11	Taste	IS-3025(Part 8)	Agreeable	Agreeable	Agreeable	-


Notes:

1. The results given above are related to the sample as received and tested in PHED Lab, JHAJJAR. Reliability of sample lies with the sender.
2. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
3. The test report can't be used for any publicity or any legal purpose.
4. The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
5. Sample is not drawn by laboratory.

(Sonia)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Jhajjar

END OF TEST REPORT


Chairman
Vijaya Educational Society
Bahadurgarh-124507 (Hr.)


Principal
Vijaya Sr. Sec. School
Lowa Khurd, Bahadurgarh



WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT,
JHAJJAR
E-mail:-chemistjr@gmail.com

PHEDJJR 7.8 F-01

Test Report

Test Report No.:-CH-822/2024	Sample quantity:- 2 Litre
Issue To:- PHESD No.2 Bahadurgarh	Issue Date:- 29.01.2024
Memo No.:-39	Sample Description:-Drinking Water
Sample Type:-Chemical Analysis	Sample Received on Date:- 23.01.2024
Sample Submitted by:- Sh. Anil	Date of Analysis Started:- 23.01.2024
Sample Location:- Vijaya Sr. Sec. School, Village Lowa Khurd	Date of Analysis Completed:- 23.01.2024

RESULTS

S. No.	Parameter	Results Mg/l	IS:10500:2012(Second Revision)(RA -2018)		Unit
			Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Fluoride	0.15	1.0	1.5	mg/l
2	Sulphate	24	200	400	mg/l
3	Nitrate	1.4	45	No Relaxation	mg/l
4	Iron	0.11	1.0	No Relaxation	mg/l
5	Free Residual Chlorine	0	0.2	1.0	mg/l

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, JHAJJAR. Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
- Sample is not drawn by laboratory.

Sonia
(Sonia)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Jhajjar

END OF TEST REPORT

[Signature]
Chairman
Vijaya Educational Society
Bahadurgarh-124507 (Hr.)

[Signature]
Principal
Vijaya Sr. Sec. School
Lowa Khurd, Bahadurgarh

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. Health / 2023 / 116Date : 27/04/23


It is certified that an inspection team headed by Dr. Rajan
Medical Officer & Devedas Kumar (MPHO) (Name of Officers
with designation) from PHC Nuna Majra (JJR) (Name of
Department/Office) inspected the Vijaya Sr. Sec School
Lowa Khurd, Bahadurgarh (JJR) (Name & Address of
the School) on 26.04.2023 and found that the Vijaya Sr. Sec
School Lowa Khurd, Bahadurgarh (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.


The above valid for a period of Six Month.


Chairman
Vijaya Educational Society
Bahadurgarh-124507 (Hr.)
To

Vijaya Sr. Sec School
Lowa Khurd, Bahadurgarh
JJR
(Name & Address of the Institution)

Signature with Seal : _____
Name उप-सिविल सर्जन
Designation कृते सिविल सर्जन
झज्जर


Principal
Vijaya Sr. Sec. School
Lowa Khurd, Bahadurgarh
PRINCIPAL
VIJAYA SR. SEC. SCHOOL
LOWA KHURD


Chairman
Vijaya Educational Society
Bahadurgarh-124507 (Hr.)



[Type here]
SH BAHADURGARH, BHAJAR

SSHLABORATORY
HARYANA

HEALTH DEPARTMENT

From
Incharge
SSHLAB
Bahadurgarh

To
No. 110
The Shiksha Nigraha

No. _____ dated 08/04/23
Subject: Bacteriological examination of water samples


Reference your letter no. _____ dated 08/04/23


The report of the water samples submitted by you are as under:


Sr. no.	Particulars of water samples	OT Test Result	Test report of water for Bacteriological examination
1	Vijaya Sr. Sec. School	POSITIVE	The probable coliform count is <u>ALL</u> per 100 ml of water Water quality is <u>EXCELLENT</u> water is <u>FIT</u> for human consumption
2			The probable coliform count is _____ per 100 ml of water Water quality is _____ Water is _____ for human consumption
3			The probable coliform count is _____ per 100 ml of water Water quality is _____ Water is _____ for human consumption
4			The probable coliform count is _____ per 100 ml of water Water quality is _____ Water is _____ for human consumption


Chairman
Vijaya Educational Society
Bahadurgarh-124507 (Hr.)

A COPY IS FORWARDED TO CIVIL SURGEON BHAJAR FOR INFORMATION AND NECESSARY ACTION
PLEASE

Incharge

Chairman
Vijaya Educational Society
Bahadurgarh-124507 (Hr.)


Principal
Vijaya Sr. Sec. School
Lowa Khurd, Bahadurgarh


PRINCIPAL
VIJAYA SR. SEC. SCHOOL
LOWA KHURD
SSHLAB BAHADURGARH